

Power-line communication

Power-line communication (also known as **power-line carrier** or **PLC**) carries data on a conductor that is also used simultaneously for AC [electric power transmission](#) or [electric power distribution](#) to consumers.

A wide range of power-line communication technologies are needed for different applications, ranging from [home automation](#) to [Internet access](#) which is often called [broadband over power lines](#) (BPL). Most PLC technologies limit themselves to one type of wires (such as premises wiring within a single building), but some can cross between two levels (for example, both the distribution network and premises wiring). Typically transformers prevent propagating the signal, which requires multiple technologies to form very large networks. Various data rates and frequencies are used in different situations.

A number of difficult technical problems are common between [wireless](#) and power-line communication, notably those of [spread spectrum](#) radio signals operating in a crowded environment. Radio interference, for example, has long been a concern of [amateur radio](#) groups.^[1]

Basics

Power-line [communications systems](#) operate by adding a modulated carrier signal to the wiring system. Different types of power-line communications use different frequency bands. Since the power distribution system was originally intended for transmission of [AC power](#) at typical frequencies of 50 or 60 [Hz](#), power wire circuits have only a limited ability to carry higher frequencies. The propagation problem is a limiting factor for each type of power-line communications.

The main issue determining the frequencies of power-line communication is laws to limit interference with radio services. Many nations regulate unshielded wired emissions as if they were radio transmitters. These jurisdictions usually require unlicensed uses to be below 500 kHz or in unlicensed radio bands. Some jurisdictions (such as the EU), regulate wire-line transmissions further. The U.S. is a notable exception, permitting limited-power wide-band signals to be injected into unshielded wiring, as long as the wiring is not designed to propagate radio waves in free space.

[Data rates](#) and distance limits vary widely over many power-line communication standards. Low-frequency (about 100–200 kHz) carriers impressed on high-voltage transmission lines may carry one or two analog voice circuits, or telemetry and control circuits with an equivalent data rate of a few hundred bits per second; however, these circuits may be many miles long. Higher data rates generally imply shorter ranges; a [local area network](#) operating at millions of bits per second may only cover one floor of an office building, but eliminates the need for installation of dedicated network cabling.

Ripple control

[Ripple control](#) adds an audio-frequency tone to an AC line. Typical frequencies are from 100Hz to 2400Hz. Each district usually has its own frequency, so that adjacent areas are unaffected. Codes are sent by slowly turning the tone on and off. Equipment at a customer site receives the codes, and turns customer equipment off and on. Often the decoder is part of a standard [electricity meter](#), and controls relays. There are also utility codes, e.g. to set the clocks of the power meters at midnight.

In this way, the utility can avoid up to 20% of capital expenses for generating equipment. This lowers costs for electricity and fuel usage. Brownouts and rolling blackouts are more easily prevented. Grids that use [cogeneration](#) can enable auxiliary customer equipment when the generators are being run to generate heat rather than electricity.

An annoyance for customers is that sometimes the code to turn equipment on is lost, or load shedding is inconvenient or dangerous. For example, during a party, a dangerous heat wave or when life-preserving medical equipment is on-site. To handle these cases, some equipment includes switches to circumvent load shedding. Some meters switch into a higher billing rate when the "party switch" is flipped.

Long haul, low frequency

Utility companies use special coupling [capacitors](#) to connect radio transmitters and receivers to the AC power carrying conductors. Power meters often use small transformers with linear amplifiers in the range of tens of watts. Most of the expense of any PLC system is the power electronics. By comparison, the electronics to encode and decode is usually small, in a special purpose integrated circuit. Thus even the complicated OFDM standards can still be economical.

Frequencies used are in the range of 24 to 500 kHz, with transmitter power levels up to hundreds of [watts](#). These signals may be impressed on one conductor, on two conductors or on all three conductors of a high-voltage AC transmission line. Several PLC channels may be coupled onto one HV line. Filtering devices are applied at substations to prevent the carrier frequency current from being bypassed through the station apparatus and to ensure that distant faults do not affect the isolated segments of the PLC system. These circuits are used for control of switchgear, and for protection of transmission lines. For example, a [protective relay](#) can use a PLC channel to trip a line if a fault is detected between its two terminals, but to leave the line in operation if the fault is elsewhere on the system.

While utility companies use microwave and now, increasingly, [fiber optic cables](#) for their primary system communication needs, the power-line carrier apparatus may still be useful as a backup channel or for very simple low-cost installations that do not warrant installing fiber optic lines, or which are inaccessible to radio or other communication.

Power-line carrier communication (PLCC) is mainly used for [telecommunication](#), tele-protection and tele-monitoring between [electrical substations](#) through [power lines](#) at [high voltages](#), such as 110 kV, 220 kV, 400 kV.^[2]

The modulation generally used in these system is [amplitude modulation](#). The carrier frequency range is used for audio signals, protection and a pilot frequency. The pilot frequency is a signal in the audio range that is transmitted continuously for failure detection.

The voice signal is compressed and filtered into the 300 Hz to 4000 Hz range, and this audio frequency is mixed with the carrier frequency. The carrier frequency is again filtered, amplified and transmitted. The transmission power of these HF carrier frequencies will be in the range of 0 to +32 [dbW](#). This range is set according to the distance between substations.

PLCC can be used for interconnecting [private branch exchanges](#) (PBXs).

To sectionalize the transmission network and protect against failures, a "wave trap" is connected in series with the power (transmission) line. They consist of one or more sections of resonant circuits, which block the high frequency carrier waves (24 kHz to 500 kHz) and let power frequency current (50 Hz – 60 Hz) pass through. Wave traps are used in switchyard of most power stations to prevent carrier from entering the station equipment. Each wave trap has a lightning arrester to protect it from surge voltages.

A coupling capacitor is used to connect the transmitters and receivers to the high voltage line. This provides low impedance path for carrier energy to HV line but blocks the power frequency circuit by being a high impedance path. The coupling capacitor may be part of a [capacitor voltage transformer](#) used for voltage measurement.

Power-line carrier systems have long been a favorite at many utilities because it allows them to reliably move data over an infrastructure that they control.

A *PLC carrier repeating station* is a facility, at which a power-line communication (PLC) signal on a [powerline](#) is refreshed. Therefore the signal is filtered out from the powerline, [demodulated](#) and [modulated](#) on a new [carrier frequency](#), and then reinjected onto the powerline again. As PLC signals can carry long distances (several hundred kilometres), such facilities only exist on very long power lines using PLC equipment.

PLC is one of the technologies used for automatic meter reading. Both one-way and two-way systems have been successfully used for decades. Interest in this application has grown substantially in recent history—not so much because there is an interest in automating a manual process, but because there is an interest in obtaining fresh data from all metered points in order to better control and operate the system. PLC is one of the technologies being used in [Advanced Metering Infrastructure](#) (AMI) systems.

In a one-way (inbound only) system, readings "bubble up" from end devices (such as meters), through the communication infrastructure, to a "master station" which publishes the readings. A

one-way system might be lower-cost than a two-way system, but also is difficult to reconfigure should the operating environment change.

In a two-way system (supporting both outbound and inbound), commands can be broadcast out from the master station to end devices (meters) – allowing for reconfiguration of the network, or to obtain readings, or to convey messages, etc. The device at the end of the network may then respond (inbound) with a message that carries the desired value. Outbound messages injected at a utility substation will propagate to all points downstream. This type of broadcast allows the communication system to simultaneously reach many thousands of devices—all of which are known to have power, and have been previously identified as candidates for load shed. PLC also may be a component of a [smart grid](#).

Medium frequency (100 kHz)

These systems are often used in countries in which it is illegal to transmit signals that interfere with normal radio. The frequencies are so low that they are unable to start radio waves when sent over the utility wiring.

Home control (narrowband)

Power-line communications technology can use the electrical power wiring within a home for [home automation](#): for example, remote control of lighting and appliances without installation of additional control wiring.

Typically home-control power-line communication devices operate by modulating in a [carrier wave](#) of between 20 and 200 kHz into the household wiring at the transmitter. The carrier is modulated by digital signals. Each receiver in the system has an address and can be individually commanded by the signals transmitted over the household wiring and decoded at the receiver. These devices may be either plugged into regular power outlets, or permanently wired in place. Since the carrier signal may propagate to nearby homes (or apartments) on the same distribution system, these control schemes have a "house address" that designates the owner. A popular technology known as [X10](#) has been used since the 1970s.^[3]

The "[universal powerline bus](#)", introduced in 1999, uses [pulse-position modulation](#) (PPM). The physical layer method is a very different scheme than the X10.^[4] [LonTalk](#), part of the [LonWorks](#) home automation product line, was accepted as part of some automation standards.^[5]

Low-speed narrow-band

Narrowband power-line communications began soon after electrical power supply became widespread. Around the year 1922 the first carrier frequency systems began to operate over high-tension lines with frequencies of 15 to 500 kHz for telemetry purposes, and this continues.^[6] Consumer products such as baby alarms have been available at least since 1940.^[7]

In the 1930s, ripple carrier signaling was introduced on the medium (10–20 kV) and low voltage (240/415 V) distribution systems.

For many years the search continued for a cheap bi-directional technology suitable for applications such as remote meter reading. French electric power *Électricité de France* (EDF) prototyped and standardized a system called "spread frequency shift keying" or S-FSK. (See [IEC 61334](#)) It is now a simple, low cost system with a long history, however it has a very slow transmission rate. In the 1970s, the Tokyo Electric Power Co ran experiments which reported successful bi-directional operation with several hundred units.^[8] The system is now (2012) widely used in Italy and some other parts of the EU.

S-FSK sends a burst of 2, 4 or 8 tones centered around the time when the AC line passes through zero voltage. In this way, the tones avoid most radio-frequency noise from arcing. (It is common for dirty insulators to arc at the highest point of the voltage, and thus generate a wide-band burst of noise.) To avoid other interference, receivers can improve their signal-to-noise ratio by measuring the power of only the "1" tones, only the "0" tones or the differential power of both. Different districts use different tone pairs to avoid interference. The bit timing is typically recovered from the boundaries between tones, in a way similar to a [UART](#). Timing is roughly centered on the zero crossing with a timer from the previous zero crossing. Typical speeds are 200 to 1200 bits per second, with one bit per tone slot. Speeds also depend on the AC line frequency. The speed is limited by noise, and the jitter of the AC line's zero crossing, which is affected by local loads. These systems are usually bidirectional, with both meters and central stations sending data and commands. Higher levels of the protocols can have stations (usually smart meters) retransmit messages. (See [IEC 61334](#))

Since the mid-1980s, there has been a surge of interest in using the potential of digital communications techniques and [digital signal processing](#). The drive is to produce a reliable system which is cheap enough to be widely installed and able to compete cost effectively with wireless solutions. But the narrowband powerline communications channel presents many technical challenges, a mathematical channel model and a survey of work is available.^[9]

Applications of mains communications vary enormously, as would be expected of such a widely available medium. One natural application of narrow band power-line communication is the control and [telemetry](#) of electrical equipment such as meters, switches, heaters and domestic appliances. A number of active developments are considering such applications from a systems point of view, such as [demand side management](#).^[10] In this, domestic appliances would intelligently co-ordinate their use of resources, for example limiting peak loads.

Control and telemetry applications include both 'utility side' applications, which involves equipment belonging to the utility company up to the domestic meter, and 'consumer-side' applications which involves equipment in the consumer's premises. Possible utility-side applications include [automatic meter reading](#) (AMR), dynamic tariff control, load management, load profile recording, credit control, pre-payment, remote connection, fraud detection and network management,^[11] and could be extended to include gas and water.

Open Smart Grid Protocol (OSGP) is one of the most proven narrowband PLC technologies and protocols for smart metering. There are more than five million smart meters, based on OSGP and using BPSK PLC, installed and operating around the World. The OSGP Alliance, a non-profit association originally established as ESNA in 2006, led an effort to establish a family of specifications published by the European Telecommunications Standards Institute (ETSI) used in conjunction with the ISO/IEC 14908 control networking standard for smart grid applications. OSGP is optimized to provide reliable and efficient delivery of command and control information for smart meters, direct load control modules, solar panels, gateways, and other smart grid devices. OSGP follows a modern, structured approach based on the OSI protocol model to meet the evolving challenges of the smart grid.

At the physical layer, OSGP currently uses ETSI 103 908 as its technology standard. This uses binary phase shift keying at 3592.98 BAUD, using a carrier tone of 86.232KHz +/- 200ppm.^[12] (Note: The bit clock is almost exactly 1/24 of the carrier.) At the OSGP application layer, ETSI TS 104 001 provides a table-oriented data storage based, in part, on the ANSI C12.19 / MC12.19 / 2012 / IEEE Std 1377 standards for Utility Industry End Device Data Tables and ANSI C12.18 / MC12.18 / IEEE Std 1701, for its services and payload encapsulation. This standard and command system provides not only for smart meters and related data but also for general purpose extension to other smart grid devices.

A project of EDF, France includes demand management, street lighting control, remote metering and billing, customer specific tariff optimisation, contract management, expense estimation and gas applications safety.^[13]

There are also many specialised niche applications which use the mains supply within the home as a convenient data link for telemetry. For example, in the UK and Europe a TV audience monitoring system uses powerline communications as a convenient data path between devices that monitor TV viewing activity in different rooms in a home and a data [concentrator](#) which is connected to a telephone modem.

Medium-speed narrow-band

The Distribution Line Carrier (DLC) System technology used a frequency range of 9 to 500 kHz with data rate up to 576 kbit/s.^[14]

A project called Real-time Energy Management via Powerlines and Internet (REMPLI) was funded from 2003 to 2006 by the [European Commission](#).^[15]

More modern systems use [OFDM](#) to send data at faster bit rates without causing radio frequency interference. These utilize hundreds of slowly-sending data channels. Usually they can adapt to noise by turning off channels with interference. The extra expense of the encoding devices is minor compared to the cost of the electronics to transmit. The transmission electronics is usually a high power operational amplifier, a coupling transformer and a power supply. Similar transmission electronics is required on older, slower systems, so with improved technology, improved performance can be very affordable.

In 2009, a group of vendors formed the PowerLine Intelligent Metering Evolution (PRIME) alliance.^[16] As delivered, the physical layer is [OFDM](#), sampled at 250 kHz, with 512 [differential phase shift keying](#) channels from 42–89 kHz. Its fastest transmission rate is 128.6 kilobits/second, while its most robust is 21.4 kbit/s. It uses a [convolutional code](#) for error detection and correction. The upper layer is usually [IPv4](#).^[17]

In 2011, several companies including distribution network operators ([ERDF](#), [Enexis](#)), meter vendors ([Sagemcom](#), [Landis&Gyr](#)) and chip vendors ([Maxim Integrated](#), [Texas Instruments](#), [STMicroelectronics](#), [Renesas](#)) founded the G3-PLC Alliance^[18] to promote G3-PLC technology. G3-PLC is the low layer protocol to enable large scale infrastructure on the electrical grid. G3-PLC may operate on CENELEC A band (35 to 91 kHz) or CENELEC B band (98 kHz to 122 kHz) in Europe, on ARIB band (155 kHz to 403 kHz) in Japan and on FCC (155 kHz to 487 kHz) for the US and the rest of the world. The technology used is [OFDM](#) sampled at 400 kHz with adaptive modulation and tone mapping. Error detection and correction is made by both a [convolutional code](#) and [Reed-Solomon error correction](#). The required [media access control](#) is taken from [IEEE](#)

802.15.4, a radio standard. In the protocol, 6LoWPAN has been chosen to adapt IPv6 an internet network layer to constrained environments which is Power line communications. 6LoWPAN integrates routing, based on the mesh network LOADng, header compression, fragmentation and security. G3-PLC has been designed for extremely robust communication based on reliable and highly secured connections between devices, including crossing Medium Voltage to Low Voltage transformers. With the use of IPv6, G3-PLC enables communication between meters, grid actuators as well as smart objects. In December 2011, G3 PLC technology was recognised as an international standard at ITU in Geneva where it is referenced as G.9903,^[19] Narrowband orthogonal frequency division multiplexing power line communication transceivers for G3-PLC networks.

Transmitting radio programs

Sometimes PLC was used for transmitting radio programs over powerlines. When operated in the AM radio band, it is known as a carrier current system.

High frequency (≥ 1 MHz)

High frequency communication may (re)use large portions of the radio spectrum for communication, or may use select (narrow) band(s), depending on the technology.

Home networking (LAN)

Power line communications can also be used in a home to interconnect home computers and peripherals, and home entertainment devices that have an Ethernet port. Powerline adapter sets plug into power outlets to establish an Ethernet connection using the existing electrical wiring in the home (power strips with filtering may absorb the power line signal). This allows devices to share data without the inconvenience of running dedicated network cables.

The widely deployed powerline networking standard are from HD-PLC Alliance (<https://hd-plc.org>) and HomePlug Powerline Alliance. But HomePlug Powerline Alliance announced in October 2016 that it would wind down its activities, and the Alliance website (<http://www.homeplug.org/> Article title) has been closed. HD-PLC, and HomePlug AV which is the most current of the HomePlug specifications were adopted by the IEEE 1901 group as baseline technologies for their standard, published 30 December 2010. HomePlug estimates that over 45 million HomePlug devices have been deployed worldwide. Other companies and organizations back

different specifications for power line home networking and these include the [Universal Powerline Association](#), [SiConnect](#), [Xsilon](#), and the ITU-T's [G.hn](#) specification.

Non-home networking (LAN)

With the diversification of IoT applications, the demand for high-speed data communication such as transmission of high-definition video data and/or high-frequency sensor data is increasing in the field of smart building, smart factory, smart city, etc. In such use cases, power line communication technologies can also be used and provides the same advantage of reusing existing cables.

[HD-PLC](#) has developed a multi-hop technology that can be used to build large-scale networks. In addition, the 4th-generation HD-PLC technology provides multiple channels, which enables high-speed and long-range communication by selecting the optimal channel.

Broadband over power line

Broadband over power line (BPL) is a system to transmit two-way data over existing AC MV (medium voltage) electrical distribution wiring, between transformers, and AC LV (low voltage) wiring between transformer and customer outlets (typically 100 to 240 V). This avoids the expense of a dedicated network of wires for data communication, and the expense of maintaining a dedicated network of antennas, radios and routers in wireless network.

BPL uses some of the same radio frequencies used for over-the-air radio systems. Modern BPL employs Wavelet-OFDM, FFT-OFDM, or [frequency-hopping spread spectrum](#) to avoid using those frequencies actually in use, though early pre-2010 BPL standards did not. The criticisms of BPL from this perspective are of pre-OPERA, pre-1905 standards.

The BPL OPERA standard is used primarily in Europe by ISPs. In North America it is used in some places (Washington Island, WI, for instance) but is more generally used by electric distribution utilities for [smart meters](#) and load management.

Since the ratification of the [IEEE 1901](#) (HD-PLC, HomePlug) LAN standard and its widespread implementation in mainstream router chipsets, the older BPL standards are not competitive for communication between AC outlets within a building, nor between the building and the transformer where MV meets LV lines.

Ultra-high frequency (≥ 100 MHz)

Even higher information rate transmissions over power line use RF through microwave frequencies transmitted via a [transverse mode](#) surface wave propagation mechanism that requires only a single conductor. An implementation of this technology is marketed as [E-Line](#). These use microwaves instead of the lower frequency bands, up to 2–20 GHz. While these may interfere with [radio astronomy](#)^[20] when used outdoors, the advantages of speeds competitive with [fibre optic](#) cables without new wiring are likely to outweigh that.

These systems claim symmetric and full duplex communication in excess of 1 Gbit/s in each direction.^[21] Multiple Wi-Fi channels with simultaneous analog television in the 2.4 and 5.0 GHz unlicensed bands have been demonstrated operating over a single medium voltage line conductor. Because the underlying propagation mode is extremely [broadband](#) (in the technical sense), it can operate anywhere in the 20 MHz – 20 GHz region. Also since it is not restricted to below 80 MHz, as is the case for high-frequency BPL, these systems can avoid the interference issues associated with use of shared spectrum with other licensed or unlicensed services.^[22]

Standards

Two distinctly different sets of standards apply to powerline networking as of early 2010.

Within homes, the [IEEE 1901](#) standards specify how, globally, existing AC wires should be employed for data purposes. The IEEE 1901 includes HD-PLC and HomePlug AV as baseline technologies. Any IEEE 1901 products can coexist and be fully interoperable between products using the same technology. On the other hand, medium-frequency home control devices remain divided, although X10 tends to be dominant. For power grid use, IEEE has approved a low-frequency (≤ 500 kHz) standard called IEEE 1901.2 in 2013.^[23]

Standards organizations

Several competing organizations have developed specifications, including the [HomePlug Powerline Alliance](#) (defunct), [Universal Powerline Association](#) (defunct), and [HD-PLC Alliance](#) (<https://hd-plc.org>) . On October 2009, the ITU-T adopted Recommendation [G.hn/G.9960](#) as a standard of networks for high-speed powerline, coax, and phoneline communications.^[24] The [National Energy Marketers Association](#) (a US trade body) was also involved in advocating for standards.^[25]

In July 2009, the IEEE Power line Communication Standards Committee approved its draft standard for broadband over power lines. The [IEEE 1901](#) final standard was published on 30 December 2010, and included features from HomePlug and [HD-PLC](#). Power line communication via IEEE 1901 and [IEEE 1905](#) compliant devices is indicated by the [nVoy](#) certification all major vendors of such devices committed to in 2013. [NIST](#) has included [IEEE 1901](#) (HD-PLC, [HomePlug AV](#)) and [ITU-T G.hn](#) as "Additional Standards Identified by NIST Subject to Further Review" for the [Smart grid in the United States](#).^[26] IEEE also came up with a low-frequency standard for long-distance smart grids called IEEE 1901.2 in 2013.^[23]

See also

- [HomePlug Powerline Alliance](#)
- [HomePNA](#)
- [IEEE 1901](#)
- [IEEE 1675-2008](#)
- [KNX \(standard\)](#)
- [List of broadband over power line deployments](#)
- [LonWorks](#)
- [Open Smart Grid Protocol](#)
- [Multimedia over Coax Alliance](#)
- [National Emergency Alarm Repeater](#)
- [Residential gateway](#)
- [Universal Powerline Association](#)
- [IEC 61334](#)
- [HD-PLC](#)

References

1. *"ARRL Strengthens the Case for Mandatory BPL Notching"* (<http://www.arrl.org/news/arrl-strengthens-the-case-for-mandatory-bpl-notching>) . News release. *American Amateur Radio League*. 2 December 2010. Retrieved 24 November 2011.

2. Stanley H. Horowitz; Arun G. Phadke (2008). *Power system relaying third edition*. John Wiley and Sons. pp. 64–65. ISBN 978-0-470-05712-4.
3. Edward B. Driscoll, Jr. "The history of X10" (http://home.planet.nl/~lhendrix/x10_history.htm) . Retrieved 22 July 2011.
4. "What is Universal (sic) Powerline Bus?" (http://pulseworx.com/UPB_.htm) . Powerline Control Systems, Inc. Retrieved 22 July 2011.
5. "Echelon Announces ISO/IEC Standardization of LonWorks® Control Networks" (<https://web.archive.org/web/20120407150936/http://www.echelon.com/company/news-room/2008/lonworksISO.htm>) . News release. Echelon Corporation. 3 December 2008. Archived from the original (<http://www.echelon.com/company/press/2008/lonworksISO.htm>) on 7 April 2012. Retrieved 22 July 2011.
6. Dostert, K (1997). "Telecommunications over the Power Distribution Grid- Possibilities and Limitations" (http://www.isplc.org/docsearch/Proceedings/1997/pdf/0563_001.pdf) (PDF). Proc 1997 Internat. Symp. On Power Line Comms and Its Applications: 1–9.
7. Broadridge, R. (1989). *Power line modems and networks* (<https://ieeexplore.ieee.org/document/20724>) . Second IEE National Conference on Telecommunications. London UK. pp. 294–296.
8. Hosono, M (26–28 October 1982). Improved Automatic meter reading and load control system and its operational achievement. 4th International Conference on Metering, Apparatus and Tariffs for Electricity Supply. IEE. pp. 90–94.
9. Cooper, D.; Jeans, T. (1 July 2002). "Narrowband, low data rate communications on the low-voltage mains in the CENELEC frequencies. I. Noise and attenuation". *IEEE Transactions on Power Delivery*. **17** (3): 718–723. doi:10.1109/TPWRD.2002.1022794 (<https://doi.org/10.1109%2FTPWRD.2002.1022794>) .
10. Newbury, J. (January 1998). "Communication requirements and standards for low voltage mains signalling". *IEEE Transactions on Power Delivery*. **13** (1): 46–52. doi:10.1109/61.660847 (<https://doi.org/10.1109%2F61.660847>) .
11. Sheppard, T J (17–19 November 1992). Mains Communications- a practical metering system. 7th International Conference on Metering Applications and Tariffs for Electricity Supply. London UK: IEE. pp. 223–227.
12. "ETSI TS 103 908 V1.1.1" (https://www.etsi.org/deliver/etsi_ts/103900_103999/103908/01.01.01_60/ts_103908v010101p.pdf) (PDF). ETSI Delivery. ETSI. Retrieved 16 August 2021.
13. Duval, G. "Applications of power-line carrier at Electricite de France". Proc 1997 Internat. Symp. On Power Line Comms and Its Applications: 76–80.

14. "Distribution Line Carrier System" (<https://web.archive.org/web/20090520004013/http://www.powerq.com.my/telecommunication/distribution-line-carrier-system>) . Power-Q Sendirian Bhd. Archived from the original (<http://www.powerq.com.my/telecommunication/distribution-line-carrier-system>) on 20 May 2009. Retrieved 22 July 2011.
15. "Real-time Energy Management via Powerlines and Internet" (<https://web.archive.org/web/20090214043341/http://www.rempli.org/>) . official web site. Archived from the original (<http://www.rempli.org/>) on 14 February 2009. Retrieved 22 July 2011.
16. "Welcome To PRIME Alliance" (<http://www.prime-alliance.org/>) . Official web site. Retrieved 22 July 2011.
17. Hoch, Martin (2011). "Comparison of PLC G3 and Prime" (http://www.lit.Int.de/papers/isplc_2011_hoch.pdf) (PDF). 2011 IEEE Symposium on Powerline Communication and Its Applications: 165–169. doi:10.1109/ISPLC.2011.5764384 (<https://doi.org/10.1109%2FISPLC.2011.5764384>) . ISBN 978-1-4244-7751-7. S2CID 13741019 (<https://api.semanticscholar.org/CorpusID:13741019>) .
18. "G3-PLC Official Web Site" (<http://www.g3-plc.com/>) . Official web site. Retrieved 6 March 2013.
19. "G.9903 ITU-T Web Page" (<http://www.itu.int/rec/T-REC-G.9903-201210-I/en>) . Official web site. Retrieved 6 March 2013.
20. <http://ntrg.cs.tcd.ie/undergrad/4ba2.05/group13/index.html#21>
21. Glenn Elmore (August 2006). "Understanding the information rate of BPL and other last-mile pipes" (<http://web.archive.org/web/20110722055823/http://www.computingunplugged.com/issues/issue200608/00001828001.html>) . Computing Unplugged magazine. Archived from the original (<http://www.computingunplugged.com/issues/issue200608/00001828001.html>) on July 22, 2011. Retrieved July 22, 2011.
22. Glenn Elmore (27 July 2009). "Introduction to the Propagating TM Wave on a Single Conductor" (<http://www.corridor.biz/FullArticle.pdf>) (PDF). Corridor Systems. Retrieved 22 July 2011.
23. IEEE P1901.2. "IEEE 1901.2-2013 - IEEE Standard for Low-Frequency (less than 500 kHz) Narrowband Power Line Communications for Smart Grid Applications" (https://standards.ieee.org/standard/1901_2-2013.html) . Retrieved 23 December 2013.
24. "New Global Standard for Fully Networked Home" (<https://web.archive.org/web/20090221090736/http://www.itu.int/ITU-T/newslog/New+Global+Standard+For+Fully+Networked+Home.aspx>) . Itu.int. 12 December 2008. Archived from the original (<http://www.itu.int/ITU-T/newslog/New+Global+Standard+For+Fully+Networked+Home.aspx>) on 21 February 2009. Retrieved 11 October 2010.
25. "NEM: National Energy Marketers Association" (<https://www.energymarketers.com/>) . www.energymarketers.com. Retrieved 14 October 2019.
26. "NIST Framework and Roadmap for Smart Grid Interoperability Standards, Release 1.0" (http://www.nist.gov/public_affairs/releases/upload/smartgrid_interoperability_final.pdf) (PDF). Nist.gov. Retrieved 8 May 2012.

Further reading

- Powerline Communication: Potential and Critical System, Existing Technologies and Prospects for Future Development <http://www.tesionline.it/default/tesi.asp?id=34078>
- Blackburn, J. L., ed. (1976). *Applied Protective Relaying*. Newark, N.J.: Westinghouse Electric Corp., Relay-Instrument Division. ISBN 9781118701515. LCCN 76008060 (<https://lcn.loc.gov/76008060>) . OCLC 2423329 (<https://www.worldcat.org/oclc/2423329>) .
- Carcelle, Xavier (2006). *Réseaux CPL par la pratique* (in French). Paris: Eyrolles. ISBN 978-2-212-11930-5. OCLC 421746698 (<https://www.worldcat.org/oclc/421746698>) .

External links

- "HD-PLC (High Definition Power Line Communication)" (<http://www.hd-plc.org/>) . *Official web site*. HD-PLC Alliance.
- OSGP Alliance (<http://www.osgp.org>)
- European Telecommunications Standards Institute (<http://www.etsi.org>)

Retrieved from

["https://en.wikipedia.org/w/index.php?title=Power-line_communication&oldid=1106437748"](https://en.wikipedia.org/w/index.php?title=Power-line_communication&oldid=1106437748)

WIKIPEDIA
